



HYDROGEOLOGIC DATABASE Chemical Analysis

[Click HERE to View Information for Well GKY](#)

TRS: 32N/02E-04J

DOH PwsID: **16961**

DOH Source #: 2

Sample Results Color Code Legend

Sample Exceeds None Secondary MCL
Primary



Owner Name: **P & R Water Association**
Well Key: **GKY** Site Type: **Well**
PWS Name: **P & R Water Association**

		Bicarbonate				Conductivity		Hardness				Turbidity					
Source	Date	Alk	As		Ca	Cl		Fe		K	Mg	Mn	Na	NO3	SO4		TDS
GwMon	8/24/1992					14	340							< 0.2			
GwMon	8/24/1992		< 0.010			16	350	0.07	150			0.420	11	< 0.2	< 10	< 0.5	
DOH	6/16/2009													< 0.2			

Select Summary Statistics

Avg As:	0.005	Avg Cl:	15.0	Avg Hardness:	150	Avg NO3:	0.10
Median As:	0.005	Median Cl:	15.0	Median Hardness:	150	Median NO3:	0.1
Max As:	0.005	Max Cl:	16.0	Max Hardness:	150	Max NO3:	0.1

Bacteria Samples (distribution): [31 sample\(s\)](#)

Disclaimer: Data presented has been collected from a variety of sources. Island County makes no guarantee as to the validity or accuracy of this data.
Please report any errors to the Island County Hydrogeologist.

Generated by the Island County Hydrogeologic Database

3 records printed on 9/17/2019

Note: Items with [blue frames and blue text](#) are clickable hyperlinks to additional information / resources.

Parameter labels with a [red fill color](#) are exhibiting an increasing trend, and those with a [green fill color](#) are exhibiting a decreasing trend.